



04/12/2021

100th Street  
ASI #41-117  
900 100th Street  
Byron Center, MI 49315

**2384-3/8 x #4**

<b>Procedure</b>	<b>Sieve/Test</b>	<b>Average</b>	<b>Unit</b>	<b>2021 Target</b>
	3/4" (19mm)	100.0	%	
	1/2" (12.5mm)	100.0	%	100-100
	3/8" (9.5mm)	98.8	%	95-100
	#4 (4.75mm)	4.6	%	0-10
	#8 (2.36mm)	1.6	%	
	#16 (1.18mm)	1.4	%	
	#30 (.6mm)	1.3	%	
	#50 (.3mm)	1.2	%	
	#100 (.15mm)	1.0	%	
	#200 (75µm)	0.84	%	
	Fractured Faces (>1)	98.7	%	
	-#200 (75um)	0.84	%	
	Wash Loss (#200/75um)	0.7	%	
	Total Moisture	2.23	%	

**Name/Title**

Dan Ferris / QC