



04/30/2021

Newport
 ASI # 58-011
 7250 Reaume Road
 Newport, MI 48166

2122-Wayne County 21AA

Procedure	Sieve/Test	Average	Unit	MDOT 21AA Wayne County
	1 1/2" (37.5mm)	100.0	%	100-100
	1" (25mm)	91.7	%	85-100
	3/4" (19mm)	80.6	%	
	1/2" (12.5mm)	61.7	%	50-75
	3/8" (9.5mm)	53.4	%	
	#4 (4.75mm)	37.2	%	
	#8 (2.36mm)	24.1	%	20-45
	#16 (1.18mm)	16.1	%	
	#30 (.6mm)	11.6	%	
	#50 (.3mm)	8.6	%	
	#100 (.15mm)	6.9	%	
	#200 (75µm)	6.06	%	4-10
	Wash Loss (#200/75um)	5.8	%	4.0-10.0

Name/Title

Josh Orshoski / QC Tech