



04/12/2021

Patterson
ASI # 03-93
3700 Patterson Rd.
Middleville, MI 49333

2408-28B

Procedure	Sieve/Test	Average	Unit	28B
	1/2" (12.5mm)	100.0	%	100-100
	3/8" (9.5mm)	99.1	%	95-100
	#4 (4.75mm)	28.1	%	25-50
	#8 (2.36mm)	8.4	%	0-15
	#16 (1.18mm)	3.3	%	
	#30 (.6mm)	1.5	%	
	#50 (.3mm)	1.0	%	
	#100 (.15mm)	0.9	%	
	#200 (75µm)	0.82	%	

Name/Title

Dan Ferris / QC